


Original	K.A. Schmersal GmbH & Co. KG Möddinghofe 30 42279 Wuppertal Germany Internet: www.schmersal.com
Declaration:	We hereby certify that the hereafter described components both in their basic design and construction conform to the applicable European Directives.
Name of the component:	EX-T. 454
Type:	See ordering code
Marking:	⊕ II 2G ib IIC T6 Gb ⊕ II 2D tb IIIC T80°C Db ⊕ II 2D ib IIIC T80°C Db
Description of the component:	Belt alignment switch / Position switch -DN version with integrated Dupline® input module ¹⁾
Relevant Directives:	Explosion Protection Directive 2014/34/EU (ATEX) ¹⁾ EMV-Directive 2014/30/EU RoHS-Directive 2011/65/EU
Applied standards:	EN 60947-5-1:2017 + AC:2020 EN IEC 60079-0:2018 EN 60079-11:2012 EN 60079-31:2014
Notified body, which approved the full quality assurance system, referred to Appendix IV, 2014/34/EU:	TÜV Rheinland Industrie Service GmbH Am Grauen Stein, 51105 Köln ID n°: 0035
Notified body for Type Examination:	TÜV Rheinland Industrie Service GmbH Am Grauen Stein, 51105 Köln ID n°: 0035
EU-Type Examination Certificate:	TÜV 17 ATEX 8004
Person authorised for the compilation of the technical documentation:	Oliver Wacker Möddinghofe 30 42279 Wuppertal
Place and date of issue:	Wuppertal, August 2, 2023



Authorised signature
Philip Schmersal
Managing Director